Signs: Fire Safety & Safe Condition



Luminaires & Light Boxes

Available in standard fluorescent or energy saving LED options, luminaries are an essential part of a company's emergency evacuation procedure. All lightboxes should be installed by qualified electricians.

Maintained - the light in these units is on constantly, and should be used in area's to which the public have access.

Non-maintained - the lights in these units are only activated in the event of a power cut. Generally used for area's which are not accessible to the public and which the users are familiar with the exit routes.

1		
Emergency Exit Boxes	Code	
Fluorescent 8 Watts, Non-Maintained (3 hours)	8200	
Fluorescent 8 Watts, Maintained (3 hours)	8201	
LED 4 Watts, Non-Maintained (3 hours)	8202	
LED 4 Watts, Maintained (3 hours)	8203	
(Please note these boxes above are supplied with an exit	0200	
arrow down legend as standard)		
Fulk Assess Disability and	0205	
Exit Arrow Right Legend	8205	HxWxD: 390 x 190 x 60mm
Exit Arrow Left Legend	8206	11XVXD. 390 X 190 X 00111111
Exit Arrow Down Legend	8204	
Suspended Exit Boxes	Code	ALCO AND
LED 4 Watts, Non-Maintained (3 hours)	8207	
LED 4 Watts, Maintained (3 hours)	8208	
(Please note these boxes above are supplied with an exit	0200	
arrow down legend as standard)		
·		
Exit Arrow Right Legend	8209	
Exit Arrow Left Legend	8210	
Replacement Chain	8211	HxWxD: 405 x 245 x 28mm